

New Mexico's Storage Future: *A Possible 2030 Scenario*

October 20, 2022

Presented to:

NM RETA Energy Storage Workshop
Santa Fe, NM


G. Loren Toole

kalmiaconsulting@gmail.com

Overview

- Since mid-2021, NM RETA has conducted ***two technical studies*** that potentially impact New Mexico's energy storage future
 - Both studies utilize planning assumptions reported in a 2020 baseline study issued by ICF International, Inc. Fairfax, Va.
 - The planning horizon represents ***2030 peak summer conditions***
 - ***Topics include:*** update of key study parameters; developable renewable (VRE) capacity; transmission plan design and system robustness; utility-scale energy storage technologies

Study 1 URL- NMRETA website



https://nmreta.com/wp-content/uploads/2022/03/RETA_2022_UPDATE_TransmissionStudy21.pdf

ICF Planning Scenarios

Component	BAU	Cleaner Economy	RTO Proxy	High Renewable Deployment
Regional Electric Load	Reference load	Electrification of other sectors	Reference load	Electrification of other sectors
State Policy (ETA)	Meet 2030 target			Exceed 2030 target by 10%
Federal Tax Credits	Project eligibility extends to the end of 2020			PTC extended through 2030
Transmission Costs	Tariff pancaking		No tariff pancaking	
Transmission Constraints	a. Limited Capacity or b. Unlimited Capacity			

Energy Transition Act (ETA) requires **50%** of IOU retail energy sales sourced from renewables by **2030**

Regional Generating Capacity

- Planned changes to renewable and conventional generating capacity in the four-state region AZ, CO, UT and NM were modeled

Thermal Additions, Retirements

State	Addition MW	Retired MW	Net MW
New Mexico	670	-1,522	-852
Arizona	996	-2,137	-1,141
Colorado	494	-1,300	-806
Utah	490	-75	415


VRE Additions

State	Solar MW	Wind MW	Net MW
New Mexico	3,800	3,149	6,949
Arizona	6,567	446	7,013
Colorado	2,047	3,376	5,423
Utah	2,987	505	3,491

- ICF assumed complete retirement of Four Corners and San Juan plants

Renewable Siting Scenarios

- By 2030 11,500 MW renewable capacity added



Collector Plan Features


- A Collector Plan is defined by a renewable siting scenario **and** associated high-voltage grid additions which consist of: New transmission lines, Upgrades of existing lines, New substations, Control devices and Transformers
- These additions require multiple development stages extending over a series of years



Red indicates upgrades of existing lines, **Green** indicates new construction

Collector Plan 1 (Centralized Renewables)

Figure 3. Transmission Additions: Collector Plan 1



(L) Transmission Line; (SS) Substation; (T) Substation transformer

Table 11. Proposed Collector Plan 1 Additions

Addition	Function	Rank	Type	Miles	By Year
(L1) 345 kV Rio Puerco to Springerville	Hub	1	New	172	2025
(L2) 345 kV Ojo to San Juan	Collector	2	Upgrade	157	2025
(L3) 345 kV Clines Corner to Ojo	Collector	3	Upgrade	79	2025
(L4) 345 kV Guadalupe to Clines Corner	Collector	4	Upgrade	40	2025
(L5) 345 kV Western Spirit to Sandia	Collector	5	New	84	2025
(L6) 345 kV Guadalupe to Rio Puerco	Collector	6	Upgrade	268	2025
(L7) 345 kV Luna to Greenlee NM	Collector	7	Upgrade	110	2030
(SS) 345 kV Springerville Substation; (SS) 345 kV Greenlee Substation; (T) 345-115 kV Willard	Ancillary	-	New/ Upgrade	-	2025- 2030
TOTAL				911	-

Additional Study Topics

- All topics were selected by NM RETA for ICF's "Update" study; they include ***technical, administrative and project development issues***
- All issues relate to New Mexico's 2030 planning horizon
- Each topic reported a list of possible Legislative or Agency-specific Actions to be taken
 - Total of 24 Actions are listed
 - 10 Actions are identified as "most effective to implement early"

Utility-scale Energy Storage Technologies

<i>Item; Page Reference</i>	Technical Findings
ETA, Renewables and Storage (Utility-scale energy storage technologies); <i>Pages 23-29</i>	<i>The energy storage market in New Mexico could increase to over 525 MW by 2030.</i> Each storage technology is positioned in different development phases, with batteries probably offering the most economic near-term option for deployment.

- Actions to Support Energy Storage Development
 - Mandate development of energy storage interconnection standards ref. NMAC 17.9.569
 - Establish state administrative policies to incentivize energy storage investments

Storage Development Factors

- NM RETA's transmission projects may be selected to include storage which could ***defer, reduce or eliminate the need for new line capacity***
 - Reduction of capacity is the most likely near-term outcome
 - Storage interconnection will be affected by factors such as operating voltage, queue access and ownership rights
 - ***Favorable siting*** includes co-location with existing or proposed transmission lines and higher projected renewable capacity; access to a host substation

Study 2 URL- NMRETA website



https://nmreta.com/wp-content/uploads/2022/10/RETA-Energy-Storage_-0922.pdf

Overview

- Assess **energy storage market status and anticipated growth** to meet New Mexico's Renewable Portfolio Standard (RPS) goals
 - Storage co-located with large-scale renewable generation, connected to the transmission system at least 100 kilovolts (kV) or higher
 - In-development by 2026 and **operating by 2030**
 - Planning assumptions are based on the 2022 "Update" Study 1


VRE Build

- ICF's ***Business as Usual (BAU)*** forecast assumes a status quo outlook for the key parameters, with no changes to current policy, transmission access or cost, and normal expected demand growth
 - VRE Build is defined by the BAU forecast ***with or without*** ICF's Economic Additions of renewables
 - Storage applications considered in Study 2 assume ICF's lower-bound VRE Build
 - Development will be limited by the rate of energizing new transmission circuits

Storage Capacity versus VRE Share


- Reference study* surveyed results from over 400 capacity planning cases reported in the US, Europe
- New Mexico's projected W:S ratio 1.5-1.6 through 2030

*<https://www.osti.gov/pages/biblio/1425569>



RPS Storage Market

- By 2030 storage discharge could exceed 280 GWh



Storage Model and Constraints

Model: Identifies “*feasible*” storage growth profiles but may not identify optimal profiles; lacks a power flow solver, so transmission limits aren’t considered; storage capital costs are reported but don’t constrain results

Constraints:

- Storage unit MWh/MW ratios up to value 8.0
- Storage power rating not to exceed 250 MW
- Storage (discharge) duration up to 1,350 hours per MW


Storage Buildout: Cases 1,2

Case 1: Unit capacities up to 9 MW, 25 to 70 MWh; a total of 24 storage plants are installed by 2030

Case 2: Unit capacities up to 3 MW, 10 to 25 MWh; a total of 68 storage plants are installed by 2030


Both cases contribute similar levels of storage power and energy to the grid but their unit capacities differ by a factor of 3; assumes installation of BESS (lithium-ion)

Storage Duration versus Unit Capacity



	<i>2.5-hour</i>	<i>5.0-hour</i>	<i>7.5-hour</i>
Units	4	12	3
Charge/discharge	Up to 760 cycles per year		


Legend



	<i>2.5-hour</i>	<i>5.0-hour</i>	<i>7.5-hour</i>
Units	26	18	12
Charge/discharge	Up to 1330 cycles per year		

Storage Capital Cost

- Cost comparable to **one** 345-kV transmission circuit



Summary: 2030 Energy Storage

- ***RPS Market:*** Possible opportunity for nearly 70 utility-scale storage plants; discharged energy could exceed 280 GWh per year by 2030
- ***Scenario:*** Two storage development cases were derived based on ICF's lower-bound level; each case utilizes a mix of 2.5-, 5- and 7.5-hour storage units
- ***Investment:*** Assuming installation of utility-scale batteries, storage capital cost equals or exceeds \$261 Million

SUPPLEMENT


- Demand Profile
- Hourly Net Demand
- Load Leveling

New Mexico's Demand Profile

- Hourly metered data representing four *typical weeks* was used to construct a state-wide net demand profile
- Combined into a chronological sequence and adjusted to fit New Mexico's forecasted 2030 annual peak, energy, and load factor
- The demand profile contains 1,753 hours
- Additional data will be needed to improve modeling accuracy during off-peak hours since it is not sufficient to capture requirements for long duration storage

Hourly Net Demand- 2030

- Due to the impact of renewable generation, New Mexico's demand profile will exhibit higher *variability*



Load Leveling- 2030

- Sample of 85 large up-ramp/down-ramp events
 - The average interval between events is 40 hours; sufficient re-charge time is available to prepare for the next up-ramp
 - Prior to storage discharge, sample hours exhibit a maximum up-ramp of 380 MW; ramps can be **reduced 50% or more** through a coordinated storage control strategy
 - Storage operates at an average power of 85 MW (maximum 216 MW)